

Hazard Register



Type FUELED GENERATOR **Location**
Make GENERIC **Sale Number** 1967
Model GENERIC. **Lot Number**
Serial Number

This item has not been tested for electrical safety.

| ID | Hazard Type | Hazard Description |
|----------|----------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 68332.1 | Thermal Conditions | EXPLOSION/FIRE FROM ENGINE, SHUT-OFF ENGINE AND LEAVE TO COOL BEFORE REFUELLING, PROVIDE FIRST AID KIT AND FIRE EXTINGUISHER FOR THE PLANT. |
| 68332.2 | Plant Structure | PLANT TIP-OVER DURING USE, ALWAYS OPERATE/UNLOAD/LOAD THE PLANT ON FIRM/STABLE GROUND. |
| 68332.3 | Plant Operation | CONDUCT DOCUMENTED PRE-OPERATIONAL CHECKS PRIOR TO EACH USE, REFER TO MANUFACTURER'S OPERATIONAL/MAINTENANCE MANUALS AS APPLICABLE. |
| 68332.4 | Guarding | ENSURE THAT THE POWERED MOVING OR ROTATING PARTS ARE GUARDED AS PER AUSTRALIAN STANDARD: SAFE GUARDING OF MACHINERY. |
| 68332.5 | Process Manual | OBTAIN SERVICE AND MAINTENANCE RECORDS (IF AVAILABLE). |
| 68332.6 | Signage | ATTACH CLEAR & VISIBLE HAZARD SIGNS RE HOT SURFACES, OPERATOR WARNINGS, ELECTRICAL WARNINGS. |
| 68332.7 | Air Quality | EXHAUST EMISSION (CARBON MONOXIDE) MAY BE HARMFUL, ENSURE THE PLANT IS OPERATED IN A WELL VENTILATED AREA |
| 68332.8 | Work Space | ENSURE CLEAR AND VISIBLE SIGNAGE ON THE CONTROL PANEL TO ENABLE SAFE USE. |
| 68332.9 | Noise | SOUND PRESSURE LEVEL NEEDS TESTING AT OPERATOR WORKSTATION. IF GREATER THAN 85dB(A), EXAMINE WAYS TO REDUCE EMISSIONS FROM THE PLANT AND ATTACH CLEAR AND VISIBLE HAZARD WARNING SIGN RE: HEARING PROTECTION. |
| 68332.10 | Flammable substances | ENSURE THAT FLAMMABLE SUBSTANCES ARE STORED IN A LOCKABLE AND BUNDED STORAGE. ENSURE THAT MATERIAL SAFETY DATA SHEETS ARE OBTAINED. WHEN REFUELLING USE A CLOSED FUNNEL SYSTEM. |
| 68332.11 | Plant Operation | OBTAIN, READ, UNDERSTAND AND FOLLOW MANUFACTURER'S INSTRUCTIONS. MANUFACTURER'S MANUAL MAY NOT BE PRESENT WITH PLANT. CONTACT THE MAUNFACTURE TO OBTINA THE MANUFACTURERS MANUAL. |
| 68332.12 | PPE | PROVIDE INFORMATION/INSTRUCTION ON STORAGE, USE, CARE AND MAINTENANCE OF PERSONAL PROTECTIVE EQUIPMENT. |
| 68332.13 | Mechanical | ENTANGLEMENT/STRIKING BY WORKPIECES EJECTING FROM AND OR WITH MOVING PARTS OF THE PLANT, THE DRIVE TO THE PLANT MUST BE STOPPED/DISCONNECTED AND THE MOVING PARTS OF THE PLANT STOPPED BEFORE MAINTENANCE AND OR REMOVING ANY OBSTRUCTIONS NEAR THE PLANT. |
| 68332.14 | Plant Operation | MACHINERY TO BE OPERATED BY DESIGANTED AND COMPETENT OPERATORS ONLY. |
| 68332.15 | Electrical | PLANT (AND/OR EQUIPMENT CONNECTED TO THE PLANT) TO BE USED WITH AN EARTH LEAKAGE CIRCUIT BREAKER TO REDUCE THE RISK OF ELECTROCUTION. |
| 68332.16 | Process Manual | SUPPLY (IF AVAILABLE) MANUFACTURER'S OPERATING INSTRUCTIONS (INCLUDING PRE-OPERATIONAL CHECKS & |

Hazard Register



| | | |
|----------|-----------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| | | PERSONAL PROTECTIVE EQUIPMENT REQUIREMENTS) AT OPERATOR WORKSTATION. |
| 68332.17 | Electrical | ENSURE THAT GROUNDING (EARTHING) OF THE PLANT IS AS PER MANUFACTURER'S RECOMMENDATIONS AND OR AUSTRALIAN STANDARD: WIRING RULES AND INSPECTED AS PER AUSTRALIAN STANDARD: IN-SERVICE SAFETY INSPECTION AND TESTING OF ELECTRICAL EQUIPMENT. |
| 68332.18 | Plant Structure | SEEK TECHNICAL ADVICE FROM THE MANUFACTURER BEFORE CARRYING ANY MODIFICATIONS TO THE PLANT. |
| 68332.19 | PLANT DAMAGE | ENSURE THAT A QUALIFIED PERSON INSPECTS THIS PLANT PRIOR TO USE IN THE WORKPLACE. |
| 68332.20 | Chemicals | CONDUCT DOCUMENTED CHEMICALS RISK ASSESSMENT FOR ALL CHEMICALS USED WITH THE PLANT |
| 68332.21 | Burns | ENSURE THE EXHAUST AND ENGINE SUROUNDS ARE GUARDED APPROPRIATELY TO REDUCE THE RISK OF BURNS. ALLOW TO COOL BEFORE UNDERTAKING MAINTENANCE. |

Health and Safety Plant Safety Purchaser Information

This plant health and safety information has been prepared by Grays for the purchaser of the plant item as required by National WHS Legislation. Whilst every effort has been made to identify all of the hazards, it should be recognised that all reasonably practicable hazards have been identified given due consideration to:

- state of knowledge about the plant item
- the availability and suitability of ways to eliminate or control the hazards
- the cost of evaluating, eliminating or controlling the hazard

Consequently, if this plant item is being purchased for use at a place of work, the purchaser is reminded of their obligations to involve and consult with employees in identifying foreseeable hazards, assess their risks and to take action to eliminate or control the risks.

In order to assess the risk, it is necessary to consider for all the identified hazards, the chance (likelihood) of something happening that would impact (consequence) on health and safety at the workplace. The following guidelines are provided to assist the purchaser in consistently carrying out an assessment of risk:

| Likelihood | Consequences |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <ul style="list-style-type: none">• Frequency and duration of exposure• Probability of occurrence of hazard or event (including part history of incidents)• Possibility to avoid / minimize or limit the damage, impact or harm• Reliability and effectiveness of existing / established systems of control | <ul style="list-style-type: none">• Assume “worst case” injury, but also competent follow-up medical and rehabilitation support• Consider forces or energy levels, highest belt tensions, size of gears, pulleys or other entrapment points and therefore body parts likely to be injured• Consider sharpness of entrapment points, surrounding parts likely to exacerbate injury, and any give in the entrapment point• Consider, will entrapment continue until plant is stopped, or can an injured part travel through the entrapment area• Are temperatures of plant, or chemicals, likely to further injure entrapped person |

The outcome of the risk assessment will be a prioritised list of risk control strategies and actions consistent with the following ratings:

Low risk- may be considered acceptable, where the existing controls in place are seen to be effective, requiring periodic monitoring for effectiveness.

Medium risk- considered to be unacceptable and requiring additional risk controls within medium to long term.

High risk – considered to be unacceptable and requiring action within the short to medium term.

Extreme risk – unacceptable, where immediate action required.

In all of these cases employees/operators must be made aware of the risk controls in place to protect them from the hazards.